JURUTERA PERUNDING INTELEK SDN BHD (598999-K)
MECHANICAL AND ELECTRICAL CONSULTING ENGINEERS
NO 22-2, 2ND FLOOR, BLOCK D, LORONG PLAZA KINGFISHER 6,
PLAZA KINGFISHER, KUALA INANAM, LIKAS,
88400 KOTA KINABALU, SABAH

PROJECT : CADANGAN PEMBINAAN BALAI BOMBA DAN KUARTERS PUTATAN, SABAH.

SITE MEMO

To	:	Alasim Omar Architect (AOA)	Your Ref	:	
Attention	:	Ar. IDr. Datu Alasim Datu Omar	Our Ref	:	JPI/A288/S.M/5

SUBJECT : TANDAS OKU WATER CLOSET (WATER PRESSURE)

In refer to site visit during Testing & Commissioning dated 17-18 January 2024 matter above referred.

1) During testing and commissioning at BBP Putatan site, Unit Kejuruteraan Mekanikal and Consultant M&E discovered the water closet is not built with cannister tank. When flush test is conducted, the water pressure flush flow is not sufficient like the other water closet on site. Upon discovery only OKU Toilet is using water closet without cannister tank.

2) To overcome such problem, a water closet with cannister tank is one of the recommended solution.

JURUTERA PERUNDING INTELEK SDN BHD * 598999-K

Issued by: ROLAND	Date 15.02.2024	Received by:	Date

Copies to: [ ] R.E [ ] [ ] [ ] JPISB