STATUS KELULUSAN BAHAN – page 1/5

Item	Bahan Bangunan (mm)	Targetted Submission Date	Supplier/ Brand/ Code	Sub 1	Comments	Sub 2	Comments	Status
1.	Anti Termite		Pestgroup Synergy Sabah S/B	04/05/2021	04/05/2021 Submit in colour	03/09/2021	06/09/2021	**LULUS**
2.	Water Proofing							
3.	Homogenous/ ceramic Tiles Floor – HT, JH, JH1 & JH2 Wall - JS		Niro Ceramic Sales & Services(M) Sdn Bhd MML Tiles	02/09/2021	Supplier telah berjumpa dengan arkitek. Sedang dalam proses			
4.	Roll Carpet CA – Roll carpet dengan 100% fiber sintetik BCF berat pile minimum 850gb/sqm 'PVC FiberGlass Reinforce Backing' dengan Kambi Kayu.							
5.	Rubber Tiles RM – 500 x 500 x 25 thickness Rough surface Rubber mat tiles							

STATUS KELULUSAN BAHAN – page 2/5

Item	Bahan Bangunan (mm)	Targetted Submission Date	Supplier/ Brand/ Code	Sub 1	Comments	Sub 2	Comments	Status
6.	Batu Bata BB – 110 tebal dinding batu bata dengan lepa simen pada kedua-dua permukaan 20 tebal (dalam dan luar) serta di cat atau mana-mana kemasan seperti dinyatakan.		CHRB BUILDING MATERIALS SDN BHD	18/08/2021	Approved (24/08/2021)			**LULUS**
7.	IBS PD – Binaan system berindustri (IBS) rujuk sistem dan butiran pengeluar yang diluluskan oleh JKR serta lepa simen 20 tebal (dalam dan luar) serta dicat atau di mana-mana kemasan seperti dinyatakan.							
8.	Dinding Akustik AK – Dinding Akustik jenis Panel Rockwool – ‘full-height’.							

STATUS KELULUSAN BAHAN – page 3/5

Item	Bahan Bangunan (mm)	Targetted Submission Date	Supplier/ Brand/ Code	Sub 1	Comments	Sub 2	Comments	Status
9.	Paint CE – Dalaman 1: coat basecoat sealer Strax, APEO (Alkyphenol Ethoxylate) free dan rendah VOC (Volatile Organic Compound) serta dengan kelulusan 'Green Label' oleh SIRIM. CTC – Luaran: 1 coat alkaline resisting primer diikuti dengan 2 coat cat 2X UV Protected Colours, Dirst Resistant, Temperature Reduction, Weather Resistant, 100% acrylic anti kulat, rendah VOC (Volatile Organic Compound) serta dengan kelulusan 'Green Label' oleh SIRIM dan fade colour dengan 6 tahun waranti.		Seamaster (Marketing) Sdn Bhd	21/09/2021	**DITOLAK** • Sila Kemukakan Sijil SIRIM Test Report untuk semakan jaminan bahan • Mohon kemukakan cadangan warna bahan (3 Cadangan) kepada pihak KPKT sebagai pengesyoran kepada pihak pelanggan untuk kelulusan			
10a.	Door and Window Frame Leaf		CHRB BUILDING MATERIALS SDN BHD PRO DESIGN	06/09/2021	**DITOLAK** • Perlu katalog Jelas • SIRIM			

STATUS KELULUSAN BAHAN – page 4/5

Item	Bahan Bangunan (mm)	Targetted Submission Date	Supplier/ Brand/ Code	Sub 1	Comments	Sub 2	Comments	Status
10b.	Aluminium Sliding & Aluminium Casement Window		Pro Design and Build	10/09/2021	Need to submit catalogue			
11.	Iron Mongery							
12.	Sanitary Fittings		Claytan	27/08/2021				
13.	Tap Fittings		Claytan	27/08/2021				
14.	Floor Traps		Onimi	27/08/2021				
15.	Ventilation Block		Pionnier Block Industries Sdn Bhd	21/09/2021	APPROVED			
16.	UPVC Gutter & Rainwater down pipe 100ø rainwater down pipe		TTS Pipes & Fittings Sdn Bhd	21/09/2021	**DITOLAK** • Mohon kemukakan bahan yang mempunyai sijil SPAN			
17.	Metal Roofing PC – 0.5 tebal bumbung jenis kepingan Polycarbonate 'Heat Ray Cut (HRC) Series type Solid Sheet with atau setara dengan warna 'tinted', l/d system bingkai keluli sederhana keras 3 tebal.		NS BlueScope Lysaght Sabah Sdn. Bhd.	09/07/2021	APPROVED (24/08/2021)		04/10/2021 Dipersetujui	**LULUS**

STATUS KELULUSAN BAHAN – page 5/5

Item	Bahan Bangunan (mm)	Targetted Submission Date	Supplier/ Brand/ Code	Sub 1	Comments	Sub 2	Comments	Status
18.	Epoxy VHD – Very heavy-duty Epoxy floor to manuf.'s spec.							
19.	Ceiling PF – Plaster Board Ceiling dengan ketebalan 12mm yang diluluskan Arkitek AL – 0.55 tebal Siling Jalur Aluminium 'Aluminium Strip Ceiling' rujuk butiran pengeluar dengan corak/warna.							
20.	Pagar Rujukan – Lukisan Pembinaan 200413/JBPMput/P1-50 200413/JBPMput/P2-51							
21.	Fire Door		FITTERS MARKETING SDN BHD	06/09/2021	09/09/2021 Approved		04/10/2021 Dipersetujui	**LULUS**
22.	Aluminium							