REMT

REQUEST FOR INFORMATION

PROJECT	: CADANGAN PEMBINAAN BALAI BOMBA DAN PENYELAMAT BEAUFORT SABAH		
ISSUED TO	: NIA .	ISSUED DATE	: 30.12.2020
ATTENTION	: AR. NOOR IZWAN RAHIM	RF Info No.	: RF Info/BOMBA/ 05
DESIGINATION	: PRINCIPLE .		
C.C	: Terence Tong (CAFK) . IR. Sherman (JPI)		

This RFI will Constitute	:		Variation Oder		Time Extension		N/A	PIC Siganture

INFORMATION REQUIRED :

- Rumah Sampah .
- discrepancy drawing between Archt, C&S and MNE.
- Floor trap location.

→ Archt - 2 nos floor trap.

→ C&S - Skuppa drain. (* on site follow C&S drawing.)

→ MNE - 1 nos floor trap.

RONNY BIN LESA
SITE AGENT
REMT UTAMA SDN. BHD.

Date Required :

ISSUED BY
Name : Designation :

Acknowledgement of Receipt :
Name : Ar. Noor Izwan Bin Rahim Date : 30 December 2020

ATTACHMENT/RESPONSE :

Please follow as per Architect's Drawings (2 nos of Floor Trap).

As agreed and verified by USB KPKT in the Design Workshop session (September 2019),

C&S and M&E Engineer should follow the nos of Floor Trap to be installed in the Rumah Sampah.

Any work that has been done and needs to be changed according to the Architect's drawings

should not involve any additional costs and your immediate action on this matter is highly expected.

C.C : Aktif FA Konsult Sdn Bhd & Jurutera Perunding Intelek Sdn Bhd

Signature :
Name : Ar. Noor Izwan b. Rahim
Position : ARKITEK
Date : 8 January 2021

LEMBAGA ARKITEK MALAYSIA
No Pendaftaran LAM : A/N 157

noor izwan architect. SP/N 157
Company Stamp