REMT

REQUEST FOR INFORMATION

PROJECT	:	CADANGAN PEMBINAAN BALAI BOMBA DAN PENYELAMAT BEAUFORT SABAH					
ISSUED TO	:	Noor Izwan Arkitek	ISSUED DATE	:	6-Jun-21		
ATTENTION	:	Ar. Noor Izwan Rahim	RF Info No.	:	RF Info/BOMBA/ARC/07		
DESIGNATION	:	Principal					
C.C	:	Aktif FA Konsult					
This RFI will Constitute	:	☐ **Variation Oder**	☐ **Time Extension**		☐ **N/A**	**PIC Siganture** _____	

INFORMATION REQUIRED : Blok Utama

1)Design for Hood at Ruang Jentera Opening

2) Please specify material use.

3) Please specify top level of the hood from ground floor level, Roller shutter size 4550 (height) x 5000 (length)

* Please refer attachment for detail.

Date Required :

ISSUED BY
Name : Sulastri Designation : QAQC

Acknowledgement of Receipt :
Name : Ar. Noor Izwan Rahim Date : 3 June 2021

ATTACHMENT/RESPONSE :

1) Design (detail) for the Awning/Hood should be provided by AFK. We discussed this matter on 4th June and AFK agreed to issue the Hood detail.
2) A combination of brick (for the vertical coping) and RC (for the Hood).
3) Top level is depending on the final thickness of the Hood, please refer detail drawing from AFK.

C.C : Aktif Fa Konsult

Signature :
Name : Ar. Noor Izwan b. Rahim
Position : ARKITEK
Date : Principal / 9 June 2021

LEMBAGA ARKITEK MALAYSIA
No Pendaftaran LAM : A/N 157

noor izwan architect SP/N 157
Company Stamp