BORANG KELULUSAN BAHAN/PEMERIKSAAN MOCK-UP

PROJEK: CADANGAN PEMBINAAN PROJEK BALAI BOMBA DAN PENYELAMAT BEAUFORT, SABAH No. Kontrak : KPKT/CPPP/JBPM/14/15/2019		Kontraktor : REMT UTAMA SDN BHD	
BUTIRAN KERJA KELULUSAN BAHAN/MOCK-UP/ DESKRIPSI ITEM SAMPEL:		Lokasi *~~Mock-up~~/ Bahan/~~Kerja~~ : Blok Utama	Tarikh: 24/08/2020
Model: Common Clay Red Bricks	Pengilang: Borneo Brick Factory Sdn Bhd	Negara Asal:. MALAYSIA	Pengedar Tempatan: Borneo Brick Factory Sdn Bhd

PERAKUAN CPP/PERUNDING (Arkitek/~~M&E/C&S~~) (***Jika projek R&B***):

Saya dengan ini mengesahkan bahawa cadangan bahan/~~peralatan~~/~~*mock-up*~~ adalah mematuhi kehendak spesifikasi dan berfungsi seperti kehendak kontrak.

Disertakan :

Katalog ☐ Lukisan ☐ Sampel Bahan [/] Spesifikasi ☐ Sijil ☐

Sampel kerja ☐ *Mock-up* ☐

Tandatangan ~~CPP~~/Perunding Arkitek/~~M&E/C&S~~*	Jawatan/Cap Rasmi
Nama : Ar. Noor Izwan Rahim	Tarikh : 24 Ogos 2020

PERAKUAN KONTRAKTOR :

Saya dengan ini berjanji akan mematuhi kehendak CPP/Perunding* dan memastikan *bahan/peralatan/mock up/kerja yang dicadangkan mengikut spesifikasi dan berfungsi seperti di dalam kontrak.

Tandatangan Wakil Kontraktor	Jawatan/Cap Rasmi
Nama : Sulastri Binti Pongot	Tarikh : 24 Ogos 2020

KEPUTUSAN JKR CPP:

Dipersetujui (*concurred*) ☐

Walaupun perkara di atas telah dipersetujui, adalah menjadi tanggungjawab kontraktor bagi memastikan *bahan/peralatan/mock up/kerja mematuhi kehendak spesifikasi dan berfungsi seperti yang telah dinyatakan di dalam kontrak.

Ditolak dan perlu kemukakan semula ☐

Tandatangan KUR*(Arkitek/M&E/C&S)/Wakil PP	Jawatan/Cap Rasmi
Nama :	Tarikh

Nota: * Potong yang tidak berkenaan

REMT

SAMPLE SUBMISSION FORM

REF. NO. : RUSB/BOMBA/SSF/028

CADANGAN PEMBINAAN PROJEK BALAI BOMBA DAN PENYELAMAT BEAUFORT, SABAH

TO : AR. NOOR IZWAN - NOOR IZWAN ARCHITECT (NIA)

FROM : SULASTRI - REMT UTAMA SDN BHD

DATE : 24 JULY 2020

MATERIAL : Common Clay Red Brick

	DESCRIPTION	COMPANY/BRAND	MODEL/TECHNICAL
1	Common Clay Red Bricks	Borneo Brick Factory Sdn Bhd	220mm x 95mm x65mm
			- Compressive strenght test result

SIGNATURE :

COMMENT : For your perusal and approval.

APPROVED/RESUBMIT :

SIGNATURE : DATE :

ATTACHMENTS : [/] YES [ ] NO

DISTRIBUTION : [ ] CLIENT [/] ARCHITECT [ ] C&S [ ] M&E

SAMPLE SUBMISSION FORM

REF. NO. : RUSB/BOMBA/SSF/028

CADANGAN PEMBINAAN PROJEK BALAI BOMBA DAN PENYELAMAT BEAUFORT, SABAH		
TO	:	AR. NOOR IZWAN - NOOR IZWAN ARCHITECT (NIA)
FROM	:	SULASTRI - REMT UTAMA SDN BHD
DATE	:	24 Ogos 2020
MATERIAL	:	Common Clay Red Brick



GTS LABORATORY SDN. BHD. (304558-D)

Ground Floor, Shoplot 22, Towering Industrial Centre
Mile 4½, Jalan Penampang, 88300 Kota Kinabalu
P.O. Box 20543, 88757 Luyang, Sabah, Malaysia
Tel: 088-712370, 713127, 713128
Fax: 088-713128
Email: gtslabtesting@gmail.com

ASPHALT & CONCRETE FIELD CONTROL
ROAD WORKS QUALITY CONTROL
MATERIALS & LABORATORY TESTING
PAVEMENT EVALUATION & DESIGN
PILE LOAD TESTING

Our ref : GTS/LAB/BRK/2020/023
Date: 30th July 2020

Borneo Brick Factory Sdn Bhd
Kota Kinabalu,
Sabah.

Dear Sir,

COMPRESSIVE STRENGTH TEST ON CLAY BRICK SAMPLES FOR MATERIAL TESTING.

As requested, three (3) numbers of compressive strength test on clay brick samples were carried out on 29th July 2020.

The test results are summarized as follows:-

Lab No.	Compressive Strength		Remarks
	MN/m^2	psi	
CB 0074	8.92	1293	Clay Brick
CB 0075	8.22	1192	--ditto--
CB 0076	9.17	1330	--ditto--

Thank you.

Yours faithfully,

LIEW SU MIN
General Manager

Enc.
LSM/ymh

Scanned with CamScanner